



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

IB Roof Systems
8181 Jetstar Drive, Suite 150
Irving, TX 75063

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: IB PVC Single Ply Roof Systems over Steel Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 11-0113.02 and consists of pages 1 through 8.
The submitted documentation was reviewed by Jorge L. Acebo



NOA No.: 15-0928.11
Expiration Date: 04/28/21
Approval Date: 04/21/16
Page 1 of 8

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply Roofing
Material: PVC
Deck Type: Steel
Maximum Design Pressure: -75 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
IB PVC Single Ply	50, 60, 80 mil thickness	ASTM D4434	Polyester reinforced PVC membrane.
IB PVC Single Ply Fleeceback	50, 60, 80 mil thickness	ASTM D4434	Polyester reinforced PVC membrane with a non-woven polyester fleeceback.
IB Water Borne Adhesive	3 gal.	Proprietary	Adhesive for bonding IB membranes to wood, concrete and glass faced polyisocyanurate insulations.

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ACFoam-II	Polyisocyanurate Insulation	Atlas Roofing Corp.
ACFoam-III	Polyisocyanurate Insulation	Atlas Roofing Corp.
ENRGY 3	Polyisocyanurate Insulation	Johns Manville Corp.
Multi-Max FA-3	Polyisocyanurate Insulation	Rmax Operating, LLC
H-Shield	Polyisocyanurate insulation	Hunter Panels, LLC
ISO 95+ GL	Polyisocyanurate foam insulation	Firestone Building Products Company, LLC

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Dekfast 12, Dekfast 14, Dekfast 15 HS	Insulation and membrane fastener	Various	SFS Intec, Inc.
2.	Dekfast IF-2-SB	Galvalume stress plate	2" round	SFS Intec, Inc.



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
3.	#12 Standard Roofgrip, #14 Roofgrip, #15 Roofgrip	Insulation and membrane fastener	Various	OMG, Inc.
4.	OMG XHD Fastener	High thread fastener for use in wood, steel and concrete decks.	Various	OMG, Inc.
5.	OMG 2-3/8 in. XHD Barbed Stress Plate	Galvalume AZ55 stress plate	2-3/8" round	OMG, Inc.
6.	Extra Load Fastener	Insulation fastener for use in wood and steel decks.	Various	SFS Intec, Inc.
7.	OMG Polymer Batten Strip	Modified polymer batten strip. Holes spaced 6" o.c.	250' long, 1" wide	OMG, Inc.
8.	OMG Metal Batten Strip	Galvalume batten strip. Holes spaced 6" or 12" o.c.	10' long, 1" wide	OMG, Inc.
9.	OMG 2-3/8" Barbed XHD Plates	Steel stress plate	2-3/8" round	OMG, Inc.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	3029864	FM 4470	02/18/08
	3014692	FM 4470	08/05/03
	2D5A9.AM	FM 4450	06/22/99
	3014751	FM 4450	08/27/03
	3012321	FM 4470	07/29/02
	3009502	FM 4470	12/21/00
	3015444	FM 4450	07/11/03
Underwriters Laboratories Inc.	02NK18635	CGSB-37.54-95	11/12/03
Exterior Research & Design, LLC	03900.05.05	TAS 114-D	05/19/05
	03903.05.06-2	TAS 114-J	05/10/06
Trinity ERD	02762.03.05-R1	TAS 114-D/TAS 114-J	12/10/07
	02642.01.05-1-R1	TAS 114-J	07/13/09
	I11110.02.09	TAS 114-J	02/05/09
	03903.05.06-2-R1	TAS 114-J	07/13/09
	I31580.10.10	ASTM D4434	10/18/10

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
FM Approval Deck Limitations	N/A	D(1), D(2), D(3), D(4)	01/01/13



APPROVED ASSEMBLIES:

Membrane Type: Single Ply, PVC, Insulated

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 80 steel decking secured to minimum 0.25 in. thick structural steel supports spaced a maximum of 6 ft o.c. with ITW Buildex Traxx/4 or Traxx/5 fasteners as maximum of 6" o.c. at each structural steel support. The deck side laps are secured with ITW Buildex Traxx/1 fasteners a maximum of 30" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type D(1): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier (Optional): Any UL or FM approved vapor Barrier may be installed on the deck or over the layer of insulation.

Fire Barrier (Optional): None.

One or more layers of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ACFoam-II, ACFoam-III Minimum 1.3" thick	N/A	N/A
ENRGY 3 Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation and membrane sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: IB PVC Single Ply mechanically fastened through the insulation as specified below:

Fastening #1: Install maximum 67" wide sheets with a 5" overlap fastened 6" o.c. using OMG XHD fasteners and OMG 2-3/8" Barbed XHD Plates or IB #15 XHD Roofing Fasteners and IB 2-3/8" Barbed Seam Plates or Dekfast 15 HS fasteners or IB XHD #15 Roofing Fasteners and Dekfast IF-2-SB plates. Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.

Maximum Design Pressure –60 psf. (See General Limitation #7)

Fastening #2: Install maximum 67" wide sheets with a 5" overlap fastened 12" o.c. using OMG XHD Fasteners and OMG 2-3/8" Barbed XHD Plates or IB #15 XHD Roofing Fasteners and IB 2-3/8" Barbed Seam Plates or Dekfast 15 HS fasteners or IB XHD #15 Roofing Fasteners and Dekfast IF-2-SB plates. Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.

Maximum Design Pressure –45 psf. (See General Limitation #7)

Maximum Design Pressure: See Fastening Options Above



Membrane Type: Single Ply, PVC, Insulated

Deck Type 2I: Steel, Insulated

Deck Description: Min. 16-22 ga., Type B, Grade 33 steel decking secured to minimum 0.25 in. thick structural steel supports spaced a maximum of 6 ft o.c. with ITW Buildex Traxx/5 fasteners as maximum of 6" o.c. at each structural steel support. The deck side laps are secured with ITW Buildex Traxx/1 fasteners a maximum of 24" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type D(2): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier (Optional): Any UL or FM approved vapor Barrier may be installed on the deck or over the layer of insulation.

Fire Barrier (Optional): None.

One or more layers of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam-II, ACFoam-III, ENRGY 3 Minimum 1.5" thick	1, 3	1:2 ft²

Note: All layers of insulation and membrane sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: IB PVC Single Ply mechanically fastened through the insulation and vapor barrier, as specified below:

Install maximum 67" wide sheets with a 5" overlap fastened 6" o.c. using OMG XHD fasteners and OMG 2-3/8" Barbed XHD Plates or IB #15 XHD Roofing Fasteners and IB 2-3/8" Barbed Seam Plates or Dekfast 15 HS fasteners or IB XHD #15 Roofing Fasteners and Dekfast IF-2-SB plates. Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #7)



Membrane Type: Single Ply, PVC, Insulated

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18-20 ga., Type B, Grade 80 steel decking with 6 ft spans secured to supports with ITW Buildex Traxx/5 fasteners as maximum of 6" o.c. The deck side laps are secured with ITW Buildex Traxx/1 fasteners a maximum of 24" o.c. **This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

System Type D(3): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier (Optional): Any UL or FM approved vapor Barrier may be installed on the deck or over the layer of insulation.

Fire Barrier (Optional): None.

One or more layers of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Any Approved Polyisocyanurate Insulation listed in Table 2 Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation and membrane sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: IB PVC Single Ply mechanically fastened through the insulation as specified below:

Fastening #1: IB PVC Single Ply roof cover sealed with 5" wide laps, min. 1.5 heat welds and secured with 1" wide OMG Polymer Batten Strip, spaced maximum 8 ft. o.c. and OMG XHD fasteners spaced maximum 6" o.c. in the batten strip. The OMG Polymer Batten Strip is sealed with a minimum 5" wide PVC cover strip sealed on both edges with min. 1.5" wide heat weld.
Maximum Design Pressure –67.5 psf. (See General Limitation #7)

Fastening #2: IB PVC Single Ply roof cover sealed with 5" wide laps, min. 1.5 heat welds and secured with 1" wide OMG Metal Batten Strip, spaced maximum 8 ft. o.c. and OMG XHD fasteners spaced maximum 6" o.c. in the metal batten. The OMG Metal Batten is sealed with a minimum 5" wide PVC cover strip sealed on both edges with minimum 1.5" wide heat weld.
Maximum Design Pressure –75 psf. (See General Limitation #7)

Maximum Design Pressure: See Fastening Options Above



Membrane Type: Single Ply, PVC, Insulated

Deck Type 2I: Steel, Insulated

Deck Description: Min. 18-22 ga., Type B, Grade 80 steel decking with 6 ft spans secured to supports with ITW Buildex Traxx/5 fasteners as maximum of 6" o.c. The deck side laps are secured with ITW Buildex Traxx/1 fasteners a maximum of 24" o.c. **This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

System Type D(4): Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Barrier (Optional): Any UL or FM approved vapor Barrier may be installed on the deck or over the layer of insulation.

Fire Barrier (Optional): None.

One or more layers of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Any Approved Polyisocyanurate Insulation listed in Table 2 Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation and membrane sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Minimum 80 mils thick IB PVC Single Ply mechanically fastened through the insulation as specified below:

Install maximum 67" wide sheets with 5" overlap fastened 6" o.c. using OMG XHD fasteners and OMG 2-3/8" Barbed XHD Plates. Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.

Maximum Design Pressure: -67.5 psf. (See General Limitation #7)



STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

